

**ENVIRONMENTAL COMPLIANCE APPROVAL**

NUMBER 0667-D6SQ6H

Issue Date: July 8, 2024

Menkes Champlain Inc.  
4711 Yonge Street, No. 1400  
Toronto, Ontario  
M2N 7E4

Site Location: 1650 Champlain Avenue  
Town of Whitby, Regional Municipality of Durham

*You have applied under section 20.2 of Part II.1 of the Environmental Protection Act, R.S.O. 1990, c. E. 19 (Environmental Protection Act) for approval of:*

the establishment of stormwater management Works to service approximately 6.79 hectares of development of industrial warehouse building, located in the Town of Whitby, Ontario, for the storage, treatment and disposal of stormwater runoff, providing Enhanced level of stormwater quality control, and attenuating post development flows to predevelopment levels for all the storm events up to and including the 100-year storm event, consisting of the following Proposed Works:

**Proposed Works:**

- **stormwater management facility (catchment area 6.79 hectares):** one (1) wet pond with a sediment forebay, located on Site C (south of future Warehouse B), receiving inflows from the proposed development, having a permanent pool storage volume of approximately 1,590 cubic metres, an extended detention storage volume of approximately 1,329 cubic metres, and a total storage volume of approximately 3,748 cubic metres including the permanent pool volume, with a total depth of 3.70 metres for the 100-year storm event, having inlet structure consisting of one (1) 1200 millimetre diameter pipe with a headwall (HW1), outlet consisting of a 450 millimetre diameter outlet pipe discharging to orifice controlled MH1, to a 600 millimetre diameter pipe with headwall (HW2), discharging to proposed stormwater infiltration area, identified below;
- **stormwater infiltration area,** located on Site C (south of future Warehouse B), providing approximately 360 cubic metres of stormwater storage through rain garden stormwater infiltration area, providing infiltration for 5 mm storm runoff, servicing

approximately 11.55 hectares of catchment area consisting of proposed development (Site A), and future development (Site B), discharging to existing storm sewers on Champlain Avenue;

including erosion/sedimentation control measures during construction and all other controls and appurtenances essential for the proper operation of the aforementioned Works;

all in accordance with the submitted application and supporting documents listed in Schedule A forming part of this Approval.

*For the purpose of this environmental compliance approval, the following definitions apply:*

1. "Approval" means this entire Environmental Compliance Approval and any Schedules attached to it;
2. "Director" means a person appointed by the Minister pursuant to section 5 of the EPA for the purposes of Part II.1 of the EPA;
3. "District Manager" means the District Manager of the appropriate local District Office of the Ministry, where the Works are geographically located;
4. "EPA" means the *Environmental Protection Act*, R.S.O. 1990, c.E.19, as amended;
5. "Licensed Engineering Practitioner" means a person who holds a licence, limited licence or temporary licence under the *Professional Engineers Act*, R.S.O. 1990, c. P.28;
6. "Ministry" means the ministry of the government of Ontario responsible for the EPA and OWRA and includes all officials, employees or other persons acting on its behalf;
7. "Owner" means Menkes Champlain Inc. and its successors and assignees;
8. "OWRA" means the *Ontario Water Resources Act*, R.S.O. 1990, c. O.40, as amended;
9. "Proposed Works" means those portions of the Works included in the Approval that are under construction or to be constructed;
10. "Works" means the approved sewage works, and includes Proposed Works

*You are hereby notified that this environmental compliance approval is issued to you subject to the terms and conditions outlined below:*

## **TERMS AND CONDITIONS**

## 1. GENERAL PROVISIONS

1. The Owner shall ensure that any person authorized to carry out work on or operate any aspect of the Works is notified of this Approval and the terms and conditions herein and shall take all reasonable measures to ensure any such person complies with the same.
2. The Owner shall design, construct, operate and maintain the Works in accordance with the conditions of this Approval.
3. Where there is a conflict between a provision of any document referred to in this Approval and the conditions of this Approval, the conditions in this Approval shall take precedence.
4. The issuance of, and compliance with the conditions of this Approval does not:
  - a. relieve any person of any obligation to comply with any provision of any applicable statute, regulation or other legal requirement, including, but not limited to, the obligation to obtain approval from the local conservation authority necessary to construct or operate the Works; or
  - b. limit in any way the authority of the Ministry to require certain steps be taken to require the Owner to furnish any further information related to compliance with this Approval.

## 2. EXPIRY OF APPROVAL

1. This Approval will cease to apply to those parts of the Works which have not been constructed within five (5) years of the date of this Approval.
2. In the event that completion and commissioning of any portion of the Works is anticipated to be more than five (5) years, the Owner shall submit an application for extension at least **twelve (12) months** prior to the end of the five (5) years from the day of issuance of this Approval. The application shall include the reason(s) for the delay, whether there is any design change(s) and a review of whether the standards applicable at the time of Approval of the Works are still applicable at the time of request for extension, to ensure the ongoing protection of the environment.

## 3. CHANGE OF OWNER

1. The Owner shall notify the District Manager and the Director, in writing, of any of the following changes within thirty (30) days of the change occurring:
  - a. change of address of Owner;
  - b. change of Owner, including address of new owner;
  - c. change of partners where the Owner is or at any time becomes a partnership, and a

copy of the most recent declaration filed under the *Business Names Act, R.S.O. 1990, c. B.17* shall be included in the notification;

- d. change of name of the corporation and a copy of the most current information filed under the *Corporations Information Act, R.S.O. 1990, c. C.39* shall be included in the notification.
2. In the event of any change in ownership of the Works, other than a change in ownership to the municipality, i.e. assumption of the Works, the Owner shall notify the succeeding owner in writing of the existence of this Approval, and a copy of such notice shall be forwarded to the District Manager and the Director.
3. The Owner shall ensure that all communications made pursuant to this condition refer to the number of this Approval.

#### **4. CONSTRUCTION OF PROPOSED WORKS**

1. Upon construction of the Works, the Owner shall prepare a statement, certified by a Licensed Engineering Practitioner, that the Works are constructed in accordance with this Approval, and upon request, shall make the written statement available for inspection by Ministry staff.
2. Within six (6) months of the construction of the Works, a set of as-built drawings showing the Works "as constructed" shall be prepared. These drawings shall be kept up to date through revision undertaken from time to time and a copy shall be retained for the operational life of the Works.

#### **5. OPERATIONS AND MAINTENANCE**

1. The Owner shall make all necessary investigations, take all necessary steps and obtain all necessary approvals so as to ensure that the physical structure, siting and operations of the Works do not constitute a safety, health or flooding hazard to the general public.
2. The Owner shall undertake an inspection of the condition of the Works, at least once a year, and undertake any necessary cleaning and maintenance to ensure that sediment, debris and excessive decaying vegetation are removed from the Works to prevent the excessive build-up of sediment, oil/grit, debris and/or decaying vegetation, to avoid reduction of the capacity and/or permeability of the Works, as applicable. The Owner shall also regularly inspect and clean out the inlet to and outlet from the Works to ensure that these are not obstructed.
3. The Owner shall construct, operate and maintain the Works with the objective that the effluent from the Works is essentially free of floating and settleable solids and does not contain oil or any other substance in amounts sufficient to create a visible film, sheen, foam or discoloration on the receiving waters.

4. The Owner shall ensure the immediate inspection of the Works after a fuel or oil spill capture and, if necessary, clean and maintain the Works to prevent the excessive buildup of oil or fuel.
5. The Owner shall ensure that the design minimum liquid retention volume(s) in the pond(s) is maintained at all times.
6. The Owner shall ensure that equipment and material for the containment, clean-up and disposal of fuel and oil and materials contaminated with such, is on hand and in good repair for immediate use in the event of:
  - a. loss of fuel or oil to the Works; or
  - b. a spill within the meaning of Part X of the EPA.
7. The Owner shall prepare an operations manual prior to the commencement of operation of the Works, that includes, but is not necessarily limited to, the following information:
  - a. operating procedures for routine/periodic operation and self-monitoring of the Stormwater Management Works;
  - b. inspection programs, including frequency of inspection, for the Works and the methods or tests employed to detect when maintenance is necessary;
  - c. repair and maintenance programs, including the frequency of repair and maintenance for the Works;
  - d. a spill prevention, control and countermeasures plan including procedures for notifying the District Manager; and
  - e. procedures for responding to environmental concerns from the public.
8. The Owner shall maintain the operations manual up to date through revisions undertaken from time to time and retain a copy at the location of the Works for as long as they are in operation. Upon request, the Owner shall make the manual available for inspection and copying by Ministry personnel.

## 6. TEMPORARY EROSION AND SEDIMENT CONTROL

1. The Owner shall install and maintain temporary sediment and erosion control measures during construction and conduct inspections **once every two (2) weeks** and after each significant storm event (a significant storm event is defined as a minimum of 25 millimetres of rain in any 24 hours period). The inspections and maintenance of the temporary sediment and erosion control measures shall continue until they are no longer required and at which time they shall be removed and all disturbed areas reinstated

properly.

2. The Owner shall maintain records of inspections and maintenance which shall be made available for inspection by the Ministry, upon request. The record shall include the name of the inspector, date of inspection, and the remedial measures, if any, undertaken to maintain the temporary sediment and erosion control measures.

## 7. RECORD KEEPING

1. The Owner shall maintain a logbook to record the results of these inspections and any cleaning and maintenance operations undertaken, and shall keep the logbook at the site for inspection by the Ministry. The logbook shall include the following:
  - a. the name of the Works;
  - b. the date and results of each inspection, maintenance and cleaning, including an estimate of the quantity of any materials removed; and
  - c. the date of each spill within the catchment area, including follow-up actions / remedial measures undertaken.
2. The Owner shall retain for a minimum of **five (5) years** from the date of their creation, or longer if requested in writing by the Director, all records and information required by this Approval.

## 8. SPILL CONTINGENCY PLAN

1. Within six (6) months from the issuance of this Approval, the Owner shall implement a spill contingency plan - that is a set of procedures describing how to mitigate the impacts of a spill within the area serviced by the Works. The Owner shall, upon request, make this plan available to Ministry staff. This plan shall include as a minimum:
  - a. the name, job title and location (address) of the Owner, person in charge, management or person(s) in control of the facility;
  - b. the name, job title and 24-hour telephone number of the person(s) responsible for activating the spill contingency plan;
  - c. a site plan drawn to scale showing the facility, nearby buildings, streets, catch-basins and manholes, drainage patterns (including direction(s) of flow in storm sewers), any receiving body(ies) of water that could potentially be significantly impacted by a spill and any features which need to be taken into account in terms of potential impacts on access and response (including physical obstructions and location of response and clean-up equipment);
  - d. steps to be taken to report, contain, clean up and dispose of contaminants following

- a spill;
  - e. a listing of telephone numbers for: local clean-up company(ies) who may be called upon to assist in responding to spills; local emergency responders including health institution(s); and Ministry Spills Action Centre 1-800-268-6060;
  - f. Safety Data Sheets (SDS) for each hazardous material which may be transported or stored within the area serviced by the Works;
  - g. the means (internal corporate procedures) by which the spill contingency plan is activated;
  - h. a description of the spill response training provided to employees assigned to work in the area serviced by the Works, the date(s) on which the training was provided and by whom;
  - i. an inventory of response and clean-up equipment available to implement the spill contingency plan, location and, date of maintenance/replacement if warranted; and
  - j. the date on which the contingency plan was prepared and subsequently, amended.
2. The spill contingency plan shall be kept in a conspicuous, readily accessible location on-site.
  3. The spill contingency plan shall be amended from time to time as required by changes in the operation of the facility.

## **9. REPORTING**

1. The Owner shall prepare performance reports on a calendar year basis by March 31 of the calendar year following the period being reported upon and submit to the District Manager upon request. The reports shall contain, but shall not be limited to, the following information pertaining to the reporting period:
  - a. a description of any operating problems encountered and corrective actions taken;
  - b. a summary of all maintenance carried out on any major structure, equipment, apparatus, mechanism or thing forming part of the Works;
  - c. a summary of any effluent quality assurance or control measures undertaken in the reporting period;
  - d. a summary of any complaints received during the reporting period and any steps taken to address the complaints;

- e. a summary of all spill or abnormal discharge events; and
  - f. any other information the District Manager requires from time to time.
2. In addition to the obligations under Part X of the EPA and O. Reg. 675/98 (Classification and Exemption of Spills and Reporting of Discharges) made under the EPA, the Owner shall, within fifteen (15) days of the occurrence of any reportable spill as provided in Part X of the EPA and O. Reg. 675/98, submit a full written report of the occurrence to the District Manager describing the cause and discovery of the spill, clean-up and recovery measures taken, preventative measures to be taken and a schedule of implementation.
  3. The Owner shall, upon request, make all manuals, plans, records, data, procedures and supporting documentation available to Ministry staff.



## **Schedule A**

1. Application for Environmental Compliance Approval, dated March 8, 2023 and received on January 17, 2024, submitted by Stantec Consulting Ltd., on behalf of Menkes Champlain Inc., along with all other supporting information, including engineering drawings submitted by Stantec Consulting Ltd.
2. Functional Servicing and Stormwater Management Report, dated May 08, 2023, for Menkes Champlain Inc., for the site located at 1650 Champlain Ave, ON, prepared by Stantec Consulting Ltd.

*The reasons for the imposition of these terms and conditions are as follows:*

1. Condition 1 is imposed to ensure that the Works are built and operated in the manner in which they were described for review and upon which approval was granted. This condition is also included to emphasize the precedence of conditions in the Approval and the practice that the Approval is based on the most current document, if several conflicting documents are submitted for review.
2. Condition 2 is included to ensure that, when the Works are constructed, the Works will meet the standards that apply at the time of construction to ensure the ongoing protection of the environment.
3. Condition 3 is included to ensure that the Ministry records are kept accurate and current with respect to approved Works and to ensure that any subsequent Owner of the Works is made aware of the Approval and continue to operate the Works in compliance with it.
4. Condition 4 included to ensure that the Works are constructed, and may be operated and maintained such that the environment is protected and deterioration, loss, injury or damage to any person or property is prevented.
5. Condition 5 is included to ensure that an operations manual governing all significant areas of operation, maintenance and repair is prepared, implemented and kept current by the Owner and made available to the Ministry. Such a manual is an integral part of the operation of the Works. Its compilation and use should assist the Owner in staff training and in identifying and planning for contingencies during possible abnormal conditions. The manual will also act as a bench-mark for Ministry staff when reviewing the Owner's operation of the Works. Furthermore, this Condition is included to ensure that the Works are operated and maintained to function as designed.
6. Condition 6 is included as installation, regular inspection and maintenance of the temporary sediment and erosion control measures is required to mitigate the impact on the downstream receiving watercourse during construction until they are no longer required.
7. Condition 7 is included to require the Owner to demonstrate on a continual basis that the quality and quantity of the effluent from the approved Works is consistent with the design and effluent objectives specified in the Approval and that the approved Works does not cause any impairment to the receiving watercourse.
8. Condition 8 is included to ensure that the Owner will implement the Spill Contingency Plan, such that the environment is protected and deterioration, loss, injury or damage to any person(s) or property is prevented.
9. Condition 9 is included to provide a performance record for future references, to ensure that

the Ministry is made aware of problems as they arise, and to provide a compliance record for all the terms and conditions outlined in this Approval, so that the Ministry can work with the Owner in resolving any problems in a timely manner.

In accordance with Section 139 of the *Environmental Protection Act*, you may by written notice served upon me, the Ontario Land Tribunal and in accordance with Section 47 of the *Environmental Bill of Rights*, 1993, the Minister of the Environment, Conservation and Parks, within 15 days after receipt of this notice, require a hearing by the Tribunal. The Minister of the Environment, Conservation and Parks will place notice of your appeal on the Environmental Registry. Section 142 of the *Environmental Protection Act* provides that the notice requiring the hearing ("the Hearing") shall state:

- a. The portions of the environmental compliance approval or each term or condition in the environmental compliance approval in respect of which the hearing is required, and;
- b. The grounds on which you intend to rely at the hearing in relation to each portion appealed.

The Notice should also include:

1. The name of the appellant;
2. The address of the appellant;
3. The environmental compliance approval number;
4. The date of the environmental compliance approval;
5. The name of the Director, and;
6. The municipality or municipalities within which the project is to be engaged in.

And the Notice should be signed and dated by the appellant.

This Notice must be served upon:

Registrar\*  
Ontario Land Tribunal  
655 Bay Street, Suite 1500  
Toronto, Ontario  
M5G 1E5  
OLT.Registrar@ontario.ca

and

The Minister of the  
Environment, Conservation  
and Parks  
777 Bay Street, 5th Floor  
Toronto, Ontario  
M7A 2J3

and

The Director appointed for the purposes  
of Part II.1 of the *Environmental  
Protection Act*  
Ministry of the Environment,  
Conservation and Parks  
135 St. Clair Avenue West, 1st Floor  
Toronto, Ontario  
M4V 1P5

**\* Further information on the Ontario Land Tribunal's requirements for an appeal can be obtained directly from the Tribunal at: Tel: (416) 212-6349 or 1 (866) 448-2248, or [www.olt.gov.on.ca](http://www.olt.gov.on.ca)**

This instrument is subject to Section 38 of the *Environmental Bill of Rights*, 1993, that allows residents of Ontario to seek leave to appeal the decision on this instrument. Residents of Ontario may seek leave to appeal within 15 days from the date this decision is placed on the Environmental Registry. By accessing the Environmental Registry at <https://ero.ontario.ca/>, you can determine when the leave to appeal period ends.

The above noted activity is approved under s.20.3 of Part II.1 of the *Environmental Protection Act*.

DATED AT TORONTO this 8th day of July, 2024

A handwritten signature in black ink that reads "A. Ahmed". The signature is written in a cursive style and is underlined with a single horizontal line.

---

Aziz Ahmed, P.Eng.

Director

appointed for the purposes of Part II.1 of the  
*Environmental Protection Act*

MS/

c: District Manager, MECP York-Durham  
Ryan Cressman, Stantec Consulting Ltd.